

TENDER NOTICE FOR THE SUPPLY AND INSTALLATION OF 60 KVA UPS

Technology Information, Forecasting and Assessment Council (TIFAC), an Autonomous Body under the Department of Science and Technology, Govt. of India, invites sealed quotations (Technical & Financial) for the supply 01 number (Auto Switching) online double conversion UPS System with 60 KVA capacity, with half-an-hour backup facility, along with the Master Panel and its installation at TIFAC. UPS purchased approx 11-12 year back.

The quotations may be submitted considering the buy-back of existing UPS (two numbers of 60 KVA Eaton Make, Power ware 9305).

Authorized dealers/suppliers of APC, Eaton, Microtek etc. are requested to send sealed quotations addressed to the In-charge (F&A), TIFAC, A-Wing, Vishwakarma Bhavan, Shaheed Jeet Singh Marg, New Delhi – 110016 so as to reach us latest by 14 January 2018.

The detailed terms & conditions and formats for technical and financial bids are given below.

Important Terms and Conditions

1. TIFAC reserves the right to cancel the tender at its sole discretion without assigning any reason.
2. No advance will be paid for the work. Payment would be released after installation, integration, testing & submission of commissioning report.
3. Bidders may submit Bids (both Technical Bid and Financial Bid) in two separate sealed envelopes, marking envelope as Technical Bid and Financial Bid respectively, and then put these two envelopes in one big envelope marked with the tender number and closing date.
4. Evaluation of bids will be done on the basis of technical specifications given in tender document. Financial bid will be opened only for those bidders who have qualified in technical evaluation.
5. Quotation must be valid for 90 days, beyond the last date of receipt of quotations.
6. Bidders are requested to visit the installation area at TIFAC office, before submission of the final quotation.
7. Bidders are advised to study carefully the terms and conditions before quoting their bid. All the pages of the bid should be signed by the bidder as a token of acceptance.

8. The rates should be indicated both in words and figures. In case of discrepancy between the figure (number) and words, the rates given in the words only will be taken as authentic and no further clarification will be sought from the bidder.
9. Incomplete / late quotations shall be rejected.
10. TIFAC reserves the Right to accept any Bid and to reject any or all Bids.
11. Installation, demonstration, and training-sessions at TIFAC office will have to be provided by the manufacturer or the vendor for the quoted system free of cost.
12. Shutdown time should be the minimum to be indicated in Technical bid.
13. The firm shall not be blacklisted by Govt. of India or its agencies
14. The sealed quotation addressed to In-charge (F&A), TIFAC, A-Wing, Vishwakarma Bhavan, Shaheed Jeet Singh Marg, New Delhi – 110016 should reach on or 14 January 2018.

In-charge (F&A)

UPS Technical Specifications

Technology	Online double converter type, with pulse-width modulation (PWM) and IGBT switches
Capacity	60 KVA
Back-up time	30 minutes
Input	3 phase
Output	3 phase, Output Should be 54 (KW) Kilowatt or Above
Output frequency	50 Hz \pm 0.1%
Total Harmonic Distortion	Less than 3%
Isolation transformer	Inbuilt copper transformer at the input of UPS
Efficiency	>94%

The following enclosures are mandatory with the submission of Technical bid

FORMAT FOR TECHNICAL BID

Name of Company/ Firm:

Particulars	Yes	No
Ink Signed Authorization letter from OEM Specific to the Tender		
Copy of Registration. / License of the firm		
Complete Address & Telephone Number of the Firm		
Last three years clientele list (Submit copy of work orders)		
Copy of GST registration certificate of the firm		
Copy of PAN of the firm		
Self attested photocopies of latest income tax return of the firm for last three financial years		
Undertaking supply, installation, commissioning and training (total time in days) from the date of award the contract		
Hardcopy of the brochure, which model you are bidding		

Provide tick mark (√) in the box

If yes, enclose relevant documents & furnish necessary information

This is to certify that I / We before signing this tender have read and fully understood all the terms and conditions, contained herein, and undertake myself/ ourselves to abide by these terms and conditions. I also understand if I do not enclose all the documents required in the tender document, my bid would be rejected without any further correspondence in this regard.

(Signature with Name & Address)

Name & contact details the firm / agency

Mobile no. of Contact Person -----

**Rates would be filled as per the following format
On agency/firm letter head**

FINANCIAL BID

To,

In-charge (F&A), TIFAC

S.No.	Detail with Model & Make	Amount in Rs.	Taxes, if any (in % & Rs.)	Total (all inclusive)
1.	Online double conversion UPS System with 60 KVA and minimum one year warranty Make Model.....			
2.	Master Panel			
3.	Maintenance free Battery (with min. three year warranty) with ½ an hour backup with full load Make			
4.	Other charges if any			
5.	Buy Back Rates (2 no. Eaton make 60 KVA), Power ware 9305			

(Note: All Taxes & other charges, if any, must be mentioned clearly; otherwise, the rates will be treated as all inclusive).

**Signature of Authorized person of the
Firm/Agency with stamp**

Date: _____

Place: _____

Name & contact details the firm / agency-----

Mobile no. of Contact Person -----